



DSA Structural Amendments under review are highlighted in GRAY

Template 14-03

2001 CBC - Chapter 14A
EXTERIOR WALL COVERINGS

Section - 1403A - VENEER

Subsection(s) - 1403A.5.3

1403A.5 Adhered Veneer

• • • •

1 **1403A.5.3 Unit size limitations.** Veneer units shall not exceed
2 36 inches (914 mm) in the greatest dimension or more than 720
3 square inches (0.46m²) in total area and shall not weigh more than
4 10 pounds per square foot (psf) (48.8 kg/m²) unless approved by
5 the *enforcement agency*.

6
7 *Units of tile, masonry, stone or terra cotta which exceed 5/8 inch*
8 *(16 mm) in thickness shall be applied as for anchored veneer*
9 *where used over exit ways or more than 20 feet (6096 mm) in*
10 *height above adjacent ground elevation.*

11
12 **EXCEPTION:** Veneer units weighing less than 3 psf (14.6 kg/m²)
13 shall not be limited in dimension or area.