



DSA Structural Amendments under review are highlighted in GRAY

**Template 19-24**

**2001 CBC - Chapter 19A**  
**CONCRETE**

**Section - 1907A - DETAILS OF REINFORCEMENT**

**Subsection(s) - 1907A.5.5 - 1907A.10.5.6**

1 **1907A.5 Placing Reinforcement.**

2 ● ● ● ●

3  
4 *1907A.5.5 Prestressing tendons shall be placed within plus or*  
5 *minus 1/4-inch (6.4mm) tolerance for member depths equal to and*  
6 *less than 8 inches (203 mm) and not to exceed the lesser of 3/8 inch*  
7 *(9.5 mm) or one third the minimum concrete cover for member*  
8 *depths greater than 8 inches (203 mm).*

9 ● ● ● ●

10  
11 **1907A.10 Lateral Reinforcement for Compression Members.**

12 ● ● ● ●

13  
14 *1907A.10.5.6 Column ties shall have hooks as specified in Sec-*  
15 *tions 1907A.1.3, Items 3 and 4, and 1921A.4.*