



DSA Structural Amendments under review are highlighted in GRAY

Template 19-29

2001 CBC - Chapter 19A
CONCRETE

Section - 1914A - WALLS

Subsection(s) - 1914A.6.1

1 **1914A.6 Nonbearing Walls.**

2

3 **1914A.6.1** *Nonbearing walls or nonbearing shear walls shall*
4 *have a thickness of not less than 4 inches (102 mm) nor a thickness*
5 *less than 1/30 of the shorter unsupported distance between vertical*
6 *or horizontal stiffening elements.*

7

8 *Where walls are supported laterally by vertical elements, the*
9 *stiffness of each vertical element shall exceed that of the tributary*
10 *area of the wall.*