



DSA Structural Amendments under review are highlighted in GRAY

Template 19-51

2001 CBC - Chapter 19A
CONCRETE

Section - 1923A - ANCHORAGE TO CONCRETE

Subsection(s) - 1923A.3.1.1

- 1 *1923A.3 Strength of Anchors.*
2
3 *1923A.3.1 General.*
4
5 *1923A.3.1.1 [For DSA/SS]* *The strength of headed bolts and*
6 *headed studs solidly cast in concrete shall be taken as the average*
7 *of 10 tests approved by the enforcement agency for each concrete*
8 *strength and anchor size. Alternatively, the strength of the anchor*
9 *shall be calculated in accordance with Sections 1923A.3.2*
10 *through 1923A.3.4. The bearing area of headed anchors shall be*
11 *at least one and one-half times the shank area.*