



DSA Structural Amendments under review are highlighted in GRAY

Template 19-60

2001 CBC - Chapter 19A
CONCRETE

Section - **1929A - TESTING AND INSPECTION**

Subsection(s) - **1929A.1**

1 ***1929A.1 Cementitious Material Test. The concrete supplier***
2 ***shall furnish to the enforcement agency certification from the ce-***
3 ***ment manufacturer that the cement proposed for use on the project***
4 ***has been manufactured and tested in compliance with the require-***
5 ***ments of ASTM C 150 for portland cement and ASTM C 595 or***
6 ***ASTM C 1157 for blended hydraulic cement, whichever is appli-***
7 ***cable. When a mineral admixture or ground granulated blast-fur-***
8 ***nace slag is proposed for use, the concrete supplier shall furnish to***
9 ***the enforcement agency certification from the manufacturer that***
10 ***they have been manufactured and tested in compliance with ASTM***
11 ***C 618 or ASTM C 989, whichever is applicable. An affidavit shall***
12 ***be provided by the concrete supplier which identifies the cementi-***
13 ***tious material used for the project by the manufacturer.s lot num-***
14 ***ber, date of shipment from the manufacturer, date of receipt of***
15 ***cementitious material by the concrete supplier, place of storage***
16 ***and date of use of the cementitious material. If such information is***
17 ***not available, one grab sample of cementitious material used on***
18 ***the project shall be taken for each day.s pour and shall be tested as***
19 ***directed by the structural engineer, architect or enforcement***
20 ***agency. See Section 1929A.6 for waiver of tests.***