



DSA Structural Amendments under review are highlighted in GRAY

Template 19-61

2001 CBC - Chapter 19A
CONCRETE

Section - 1929A - TESTING AND INSPECTION

Subsection(s) - 1929A.2

1 *1929A.2 Tests of Reinforcing Bars. Where samples are taken*
2 *from bundles as delivered from the mill, with the bundles identified*
3 *as to heat number and provided the mill analyses accompany the*
4 *report, one tensile test and one bend test shall be made from a*
5 *specimen from each 10 tons (9080 kg) or fraction thereof of each*
6 *size of reinforcing steel.*
7
8 *Where positive identification of the heat number cannot be*
9 *made or where random samples are to be taken, one series of tests*
10 *shall be made from each 2-1/2 tons (2270 kg) or fraction thereof of*
11 *each size of reinforcing steel. See Section 1929A.6 for waiver of*
12 *tests.*