



DSA Structural Amendments under review are highlighted in GRAY

Template 21-02

2001 CBC - Chapter 21A
MASONRY

Section - 2102A - MATERIAL STANDARDS

Subsection(s) - 2102A.2 - Cement

1 **2102A.2 Standards of Quality.** The standards listed below
2 labeled a.UBCStandard. are also listed inChapter 35, Part II, and
3 are part of this code. The other standards listed below are *Ameri-*
4 *can Society for Testing and Materials (ASTM) or American Con-*
5 *crete Institute (ACI) staandards and are part of this code. See*
6 *Sections 3503 and 3504.*

7 ● ● ● ●

8

9 **2. Cement.**

10

11 2.1 *Not adopted by the State of California.*

12

13 2.2 *ASTMC 150, Portland Cement, Cement for mortar and*
14 *grout shall be Type I, II or III portland cement or Type*
15 *I-A, II-A or III-A air-entraining portland cement as set*
16 *forth in UBC Standard 26-1, Part I. Masonry cement or*
17 *plastic cement shall not be used in mortar or grout un-*
18 *less specifically approved by the enforcement agency.*

19

20 2.3 *UBC Standard 21-14, Mortar Cement, except the maxi-*
21 *mum limit for fly ash indicated in Table 21-14-B shall be*
22 *15 percent.*