



DSA Structural Amendments under review are highlighted in GRAY

Template 21-03

2001 CBC - Chapter 21A
MASONRY

Section - 2102A - MATERIAL STANDARDS

Subsection(s) - 2102A.2 - Masonry Units of clay or shale

1 **2102A.2 Standards of Quality.**

2 ● ● ● ●

3

4

4. Masonry units of clay or shale.

5

6

4.1 *Not adopted by the State of California.*

7

8

4.2 *Not adopted by the State of California.*

9

10

4.3 UBC Standard 21-1, Section 21.101, Building Brick (solid units), *Grade NW units shall not be used. Where severe frost action occurs in the presence of moisture, brick shall be at least Grade SW.*

11

12

13

14

15

4.4 ASTM C 126, Ceramic Glazed Structural Clay Facing Tile, Facing Brick and Solid Masonry Units. Load-bearing glazed brick shall conform to the weathering and structural requirements of UBC Standard 21-1, Section 21.106, Facing Brick

16

17

18

19

20

21

4.5 *Not adopted by the State of California.*

22

23

4.6 UBC Standard 21-1, Section 21.107, Hollow Brick

24

25

4.7 ASTM C 67, Sampling and Testing Brick and Structural Clay Tile

26

27

28

4.8 *Not adopted by the State of California.*

29

30

4.9 *Not adopted by the State of California.*