



DSA Structural Amendments under review are highlighted in GRAY

Template 21-15

2001 CBC - Chapter 21A
MASONRY

Section - 2104A - CONSTRUCTION

Subsection(s) - 2104A.6.2

1 2104A.6 Grouted Masonry.

2 ● ● ● ●

3
4 **2104A.6.2 Construction requirements.** Reinforcement *and*
5 *embedded items* shall be placed *and securely anchored against*
6 *moving* prior to grouting. Bolts shall be accurately set with tem-
7 plates or by approved equivalent means and held in place to pre-
8 vent dislocation during grouting.

9
10 Segregation of the grout materials and damage to the masonry
11 shall be avoided during the grouting process.

12
13 Grout shall be consolidated by mechanical vibration during
14 placement before loss of plasticity in a manner to fill the grout
15 space. Grout pours greater than 12 inches (300 mm) in height shall
16 be reconsolidated by mechanical vibration to minimize voids due
17 to water loss. *Grout not mechanically vibrated shall be puddled.*