



DSA Structural Amendments under review are highlighted in GRAY

Template 21-33

2001 CBC - Chapter 21A
MASONRY

Section - 2107A - WORKING STRESS DESIGN OF
MASONRY

Subsection(s) - 2107A.2.13 - 2107A.2.13.1

1 2107A.2 Design of Reinforced Masonry.

2 ● ● ● ●

3

4 2107A.2.13 Reinforcement for columns. Columns shall be pro-
5 vided with reinforcement as specified in this section.

6

7 2107A.2.13.1 Vertical reinforcement. The area of vertical
8 reinforcement shall not be less than $0.005 A_e$ and not more than
9 $0.04 A_e$. At least four No. 3 bars shall be provided. *The bars shall*
10 *not be less than No. 4 or greater than No. 11. Welded splices shall*
11 *be full butt welded.* The minimum clear distance between parallel
12 bars in columns shall be two and one half times the bar diameter.