



DSA Structural Amendments under review are highlighted in GRAY

Template 22-14

2001 CBC - Chapter 22A
STEEL

Section - 2220A - SPECIAL REQUIREMENTS IN SEISMIC ZONES 3 AND 4

Subsection(s) - 2220A.1 - 2220A.2

1 **2220A.1 General.** In Seismic Zones 3 and 4, in addition to the
2 requirements of Section 2219A, steel stud wall systems may be
3 used to resist the specified seismic forces in buildings not over
4 *three* stories in height. Such systems shall comply with the follow-
5 ing:

6 ● ● ● ●

7
8 **2220A.2 Boundary Members and Anchorage.** Boundary
9 members and the uplift anchorage thereto shall have the strength
10 to resist the forces determined by the *following* load *modifica-*
11 *tions*:

12
13 1. Axial compression $1.0P_{DL} + 0.7P_{LL} + oP_E$

14
15 2. Axial tension $0.85P_{DL} + oP_E$