



DSA Structural Amendments under review are highlighted in Marginal Markings

Template 23-11

2001 CBC - Chapter 23A
WOOD

Section - TABLES

Subsection(s) - TABLE 24A-II-B-1

SEE NEXT PAGE

FOOTNOTES TO TABLE 23A-II-B-1.(Continued)

- ⁸Corrosion-resistant roofing nails with 7/16-inch-diameter (11 mm) head and 1 1/2-inch (38 mm) length for 1/2-inch (12.7 mm) sheathing and 1 3/4-inch (44 mm) length for 25/32-inch (20 mm) sheathing conforming to the requirements of Section 2304A.3.
- ⁹Corrosion-resistant staples with nominal 7/16-inch (11 mm) crown and 1 1/8-inch (29 mm) length for 1/2-inch (12.7 mm) sheathing and 1 1/2-inch (38 mm) length for 25/32-inch (20 mm) sheathing conforming to the requirements of Section 2304A.3.
- ¹⁰Panel supports at 16 inches (406 mm) [20 inches (508 mm) if strength axis in the long direction of the panel, unless otherwise marked]. Casing or finish nails spaced 6 inches (152 mm) on panel edges, 12 inches (305 mm) at intermediate supports.
- ¹¹Panel supports at 24 inches (610 mm). Casing or finish nails spaced 6 inches (152 mm) on panel edges, 12 inches (305 mm) at intermediate supports.
- ¹²*When possible, nails driven perpendicular to the grain shall be used instead of toenails*