



DSA Structural Amendments under review are highlighted in GRAY

Template 25-10

2001 CBC - Chapter 25A
GYPSUM BOARD AND PLASTER

Section - 2506A - EXTERIOR LATH

Subsection(s) - 2506A.5

1 **2506A.5 Application of Metal Plaster Bases.** The application
2 of metal lath or wire fabric lath shall be as specified in Section
3 2505A.3 and they shall be furred out from vertical supports or
4 backing not less than 1/4 inch (6.4 mm) except as set forth in Table
5 25A-B, Footnote 2.

6
7 *Where exterior lath is attached to horizontal wood supports, ei-*
8 *ther of the following attachments shall be used in addition to the*
9 *methods of attachment set forth in Table 25A-C:*

10
11 *1. Secure lath to alternate supports with ties consisting of a*
12 *double strand of No. 18 W & M gage galvanized annealed wire at*
13 *one edge of each sheet of lath. Wire ties shall be installed not less*
14 *than 3 inches (76 mm) back from the edge of each sheet and shall*
15 *be looped around stripping, or attached to an 8d common wire*
16 *nail driven into each side of the joist 2 inches (51 mm) above the*
17 *bottom of the joist or to each end of a 16d common wire nail driven*
18 *horizontally through the joist 2 inches (51 mm) above the bottom*
19 *of the joist and the ends of the wire secured together with three*
20 *twists of the wire.*

21
22 *2. Secure lath to each support with 1/2-inch-wide (12.7 mm),*
23 *1-1/2-inch-long (38mm) No. 9W&M gage ring shank, hook staple*
24 *placed around a 10d common nail laid flat under the surface of the*
25 *lath not more than 3 inches (76 mm) from edge of each sheet. Such*
26 *staples may be placed over ribs of 3/8-inch (9.5 mm) rib lath or*
27 *over back wire of welded wire fabric or other approved lath, omit-*
28 *ting the 10d nails.*

29
30 *A weep screed shall be provided at the foundation plate line on*
31 *all exterior stud walls. The screed shall be of a type which will al-*

32 *low trapped water to drain to the exterior of the building. The*
33 *weather-resistant barrier and exterior lath shall cover and termi-*
34 *nate on the attachment flange of the screed.*

35 ● ● ● ●